



New-Indy Catawba LLC  
Catawba, South Carolina

---

**Public Notification of Downtime Activity: ONGOING**  
**June 14, 2023**

In accordance with Paragraph 1 of Appendix “A” of the US Environmental Protection Agency (“EPA”) Consent Decree dated November 16, 2022 (Civil No. 0:21-cv-02053-SAL), and New-Indy Catawba LLC’s (“New-Indy”) Public Notification Plan dated May 17, 2021, New-Indy presents the following Public Notification.

**Description of Unplanned Activity:**

The steam stripper was taken down for unplanned and necessary repairs to the stripper feed pump.

**Purpose of Activity:**

Excess vibration of the stripper feed pump required immediate repairs and replacement. During this unplanned activity, New-Indy shall maintain the condensate monitoring and pretreatment system to proactively mitigate and take all steps necessary to minimize any potential release of hydrogen sulfide.

**Activity Status:**

Start of downtime	<i>June 14, 2023 7:20 am</i>
Duration	<i>Estimated June 14, 2023 6:00 pm. Estimated duration 10 hrs 40 min</i>
Monitoring & Controls	<i>Functioning</i> <input checked="" type="checkbox"/>

**Contact Information:**

New-Indy may be reached at [catawba.info@new-indycb.com](mailto:catawba.info@new-indycb.com) concerning this activity.