



New-Indy Catawba LLC
Catawba, South Carolina

Public Notification of Downtime Activity: COMPLETE
June 18, 2023

In accordance with Paragraph 1 of Appendix “A” of the US Environmental Protection Agency (“EPA”) Consent Decree dated November 16, 2022 (Civil No. 0:21-cv-02053-SAL), and New-Indy Catawba LLC’s (“New-Indy”) Public Notification Plan dated May 17, 2021, New-Indy presents the following Public Notification.

Description of Activity:

The steam stripper was offline for unplanned issues.

PLANNED

UNPLANNED

Purpose of Activity:

This event was a result of a sheared coupling on the stripped condensate pump which caused a high level in the stripper column. Repairs to the stripped condensate pump were completed and the stripper returned to service. During this event, the flow of foul condensate through the hard pipe to the ASB was kept in ORP control with no excursions.

Activity Status:

Event 1	<i>June 18, 2023 (7:07 pm to 1:56 am June 19, 2023), 423 minutes duration</i>		
ORP Monitoring & Controls	<i>Functioning</i> <input checked="" type="checkbox"/>	<i>Excursions: No</i> <input checked="" type="checkbox"/> <i>Yes</i> <input type="checkbox"/>	<i>N/A</i>
Current Status	<i>Work is Complete</i> <input checked="" type="checkbox"/>		<i>Stripper is Online</i> <input checked="" type="checkbox"/>

Contact Information:

New-Indy may be reached at catawbainfo@new-indy.com concerning this activity.