



New-Indy Catawba LLC
Catawba, South Carolina

Public Notification of Downtime Activity: COMPLETE
June 28, 2023

In accordance with Paragraph 1 of Appendix “A” of the US Environmental Protection Agency (“EPA”) Consent Decree dated November 16, 2022 (Civil No. 0:21-cv-02053-SAL), and New-Indy Catawba LLC’s (“New-Indy”) Public Notification Plan dated May 17, 2021, New-Indy presents the following Public Notification.

Description of Activity:

The steam stripper was offline for unplanned issues.

PLANNED

UNPLANNED

Purpose of Activity:

Upsets to evaporators reduced the amount of foul condensate to the stripper below operating setpoints. Repairs were made to the evaporators and they were returned to service. This increased foul condensate flows sufficient to resume operation of the stripper. During this event, there was no flow of foul condensate through the hard pipe to the ASB and ORP controls were maintained with no excursions.

Activity Status:

Event 1	<i>June 28, 2023 (9:00 pm to 11:20 pm), 140 minutes duration</i>		
ORP Monitoring & Controls	<i>Functioning</i> <input checked="" type="checkbox"/>	<i>Excursions: No</i> <input checked="" type="checkbox"/> <i>Yes</i> <input type="checkbox"/>	<i>N/A</i>
Current Status	<i>Work is Complete</i> <input checked="" type="checkbox"/>		<i>Stripper is Online</i> <input checked="" type="checkbox"/>

Contact Information:

New-Indy may be reached at catawbainfo@new-indy.com concerning this activity.