



New-Indy Catawba LLC
Catawba, South Carolina

Public Notification of Downtime Activity: COMPLETE
January 18, 2024

In accordance with Paragraph 1 of Appendix “A” of the US Environmental Protection Agency (“EPA”) Consent Decree dated November 16, 2022 (Civil No. 0:21-cv-02053-SAL), and New-Indy Catawba LLC’s (“New-Indy”) Public Notification Plan dated May 17, 2021, New-Indy presents the following Public Notification.

Description of Activity:

The steam stripper was taken down when Combination Boiler 1 tripped unexpectedly.

PLANNED

UNPLANNED

Purpose of Activity:

The steam stripper was taken down when Combination Boiler 1 tripped unexpectedly. During this downtime activity, New-Indy maintained the condensate monitoring and pretreatment system to proactively mitigate and took all steps necessary to minimize any potential release of hydrogen sulfide.

Activity Status:

Start of downtime	<i>January 17, 2024 at 08:37</i>		
Duration	<i>January 17, 2024 at 12:51; Duration 212 minutes</i>		
Monitoring & Controls	<i>Functioning</i> <input checked="" type="checkbox"/>	<i>Excursions: No</i> <input checked="" type="checkbox"/> <i>Yes</i> <input type="checkbox"/>	
Current Status	<i>Work is Complete</i> <input checked="" type="checkbox"/>		<i>Stripper is Online</i> <input checked="" type="checkbox"/>

Contact Information:

New-Indy may be reached at catawba.info@new-indycb.com concerning this activity.