



New-Indy Catawba LLC
Catawba, South Carolina

Public Notification of Downtime Activity: COMPLETE
May 7, 2024

In accordance with Paragraph 1 of Appendix “A” of the US Environmental Protection Agency (“EPA”) Consent Decree dated November 16, 2022 (Civil No. 0:21-cv-02053-SAL), and New-Indy Catawba LLC’s (“New-Indy”) Public Notification Plan dated May 17, 2021, New-Indy presents the following Public Notification.

Description of Activity:

The steam stripper was taken down for necessary repairs to two safety relief valves.

PLANNED

UNPLANNED

Purpose of Activity:

The Catawba Mill is starting up from the Annual Outage event where mill operations have been shut down for annual maintenance/repair/inspection activities. Two safety relief valves replaced during the outage needed to be swapped. Throughout this event, the wastewater treatment facility has been fully operational. During intermediate startup and shutdown periods where condensates are being generated, New-Indy has maintained the condensate monitoring and pretreatment system to proactively mitigate and take all steps necessary to minimize any potential release of hydrogen sulfide.

Activity Status:

| | | | |
|-----------------------|---|---|---|
| Start of downtime | <i>May 6, 2024 at 14:00</i> | | |
| Duration | <i>May 6, 2024 at 20:43; Duration 403 minutes</i> | | |
| Monitoring & Controls | <i>Functioning</i> <input checked="" type="checkbox"/> | <i>Excursions: No</i> <input checked="" type="checkbox"/> | <i>Yes</i> <input type="checkbox"/> |
| Current Status | <i>Work is Complete</i> <input checked="" type="checkbox"/> | | <i>Stripper is Online</i> <input checked="" type="checkbox"/> |

Contact Information:

New-Indy may be reached at catawba.info@new-indy.cb.com concerning this activity.